

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene informacion muy importante sobre su agua potable.
Traduzcalo o hable con alguien que lo entienda bien.

City of Lemoore has Levels of Total Trihalomethanes above Drinking Water Standards

The City of Lemoore water system recently failed a drinking water standard. Although this is not an emergency, as water customers, you have a right to know what you should do, what happened, and what the City is doing to correct the situation. The City routinely monitors for the presence of drinking water contaminants. During the First Quarter of 2019, testing results showed that the system exceeded the standard or maximum contaminant level for Total Trihalomethanes in four of four results. The standards for Total Trihalomethanes (TTHM) is 80 micrograms per liter (ug/L – parts per billion).

What do I need to do?

- You **do not** need to use an alternative (such as bottled or boiled) water.
- This is not an immediate risk. If there was any risk, customers would be notified immediately. Some people who drink water-containing trihalomethanes over many years in excess of the standard may experience liver, kidney, or central nervous system problems, and may have an increased risk of cancer. If you have other health issues concerning the consumption of this water, consult your doctor.

What happened?

The Total Trihalomethanes and Haloacetic Acids quarterly monitoring and location running averages shown below:

2019 1 st Quarter Results	TTHM	HAA5	Locational Running Average	TTHM	HAA5
ST2S1	210	42	ST2S1	129.5	34.5
ST2S2	170	36	ST2S2	165.0	38.3
ST2S3	140	31	ST2S3	135.0	34.5
ST2S4	140	29	ST2S4	116.5	29.8

What is the City doing?

1. During the months of January, February and March of 2019. The City of Lemoore released a Request For Qualifications (RFQ) to contractors builders exchange. The City of Lemoore also interviews professional contract services to assist as project managers during the design build process. After receiving RFQ applications from three contractors. The City of Lemoore and Adedge held a meeting to exchange questions and answers with the three contractors. City council approved the contract with Vanir Construction as project manager. Building contractor interviews were conducted. A design build team was successfully selected and pending city council final approval.
2. City of Lemoore secured the 2019 Water Bond to fund TTHM project.

For more information, please contact the Lemoore Water Department at (559) 924-6744 or at 711 W. Cinnamon Drive.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS OR OPERATORS: Must notify** employees of businesses located on the property.

This notice is being sent to you by the City of Lemoore.