

1. DRAWINGS SHOW TYPICAL ARRANGEMENT OF EQUIPMENT. DETAILED DIMENSIONS SHALL BE PER MANUFACTURERS RECOMMENDATION AND AS APPROVED BY THE ENGINEER. SEE CITY STANDARD SPECIFICATION FOR WET WELL LIFT STATIONS.
2. ALL ANCHOR BOLTS, NUTS, BOLTS AND OTHER HARDWARE USED ON OR WITHIN WET WELL SHALL BE STAINLESS STEEL.
3. FOR COATING REQUIREMENTS, SEE CITY OF LEMOORE STANDARD SPECIFICATIONS SECTION 31, PAINTING.
4. ALL PUMP DISCHARGE PIPING AND FITTINGS IN WET WELL AND VALVE VAULT SHALL BE CLASS 150 FLANGED DUCTILE IRON WITH FUSION BONDED EPOXY LININGS AND COATINGS, UNLESS OTHERWISE NOTED ON PLANS.
5. INTERIOR WALLS AND CEILING OF WET WELL ARE TO BE T-LOCK LINED.
6. PROVIDE EXTERIOR WATER PROOFING ON ALL WALLS AND UNDER BASE OF WET WELL IN ACCORDANCE WITH THE CONTRACT SPECIFICATION AND NOTES ON DRAWINGS.
7. CONCRETE SHALL BE 4000 PSI.

1. CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL PIPE FITTINGS & VALVES WITH THE SELECTED PUMP MODEL.
2. CONTRACTOR SHALL VERIFY & BE RESPONSIBLE FOR THE CONCRETE VAULT SIZE WITH SELECTED VAULT VALVES.

