



711 W. Cinnamon Drive • Lemoore, California 93245 • (559) 924-6744 • Fax (559) 924-6708
Public Works Department

October 4, 2021
ADDENDUM NO. 4

The following shall become part of the bid packet for the Hess Basin Channel Project.

1. The City of Lemoore is hereby extending the bid closing date in order to provide bidders more time.

The deadline to submit bids has been extended to:

Friday, October 8, 2021

Many of the questions that were asked in the field have been answered as part of the revised plans in Addendum No. 3 and the remaining are answered below.

Question: Can native material be used as backfill?

Answer: yes, as long as material is backfilled before clumping occurs and meets all specifications outlined in the notes in detail "D" sheet No. 5.

Question: Pipe anchors originally called for 50. The new plans; note 5 on revise sheet 4 has conflicting verbiage. Will anchors be required the entire length or just from Station 9+50 to 15+00?

Answer: Anchors are only required between station 9+50 to 15+00. Anchors are placed 10' on center therefore 50 anchors is all that's is required.

Question: Will bidders be provided with an Engineers estimate?

Answer: No, but we have a range of \$450,000-\$500,000 (without contingency)

Question: Is Caltrans Headwall Standard detail D89 outdated?

Answer: No.



711 W. Cinnamon Drive • Lemoore, California 93245 • (559) 924-6744 • Fax (559) 924-6708
Public Works Department

Bids must be filed with the City Clerk at 711 W. Cinnamon Drive, Lemoore, California, prior to 2:00 p.m., the 8th day of October, 2021, at which time the City Clerk will open said bids. Bids shall be submitted in sealed envelopes and marked: Bid Proposal: Hess Basin Drainage Channel Project

All other requirements and dates for the bid are as posted in the original packet and addendums. If you have any questions, please contact Amanda Champion at achampion@lemoore.com or Frank Rivera at frivera@lemoore.com.

Respectfully,

Frank Rivera
Public Works Director
City of Lemoore

NOTICE: The Bidder shall SIGN and attach this addendum to their bid. No bid shall be considered unless this addendum is signed and attached thereto.

BIDDER'S SIGNATURE

DATE