

ADDENDUM NUMBER 2

FOR THE

CITY OF LEMOORE

D STREET IMPROVEMENT PROJECT

March 14, 2025



OWNER:
City of Lemoore
711 W. Cinnamon Drive
Lemoore, CA 93245
(559) 924-6700

PREPARED BY:
A&M Consulting Engineers
220 N Locust Street
Visalia, CA 93291
(559) 429-4747

ADDENDUM NUMBER 2

The following additions, deletions, or modifications shall become part of the Contract Documents for the City of Lemoore D Street Improvement Project:

CONTRACTOR QUESTIONS:

Q1: Will the V-gutters have to be poured half at a time, or can we close the access?

A1: The V-gutters shall be installed in a phased pour, half at a time to maintain vehicular access. The contractor shall implement proper bonding and finishing techniques between pours to mitigate the risk of cold joints.

Q2: Can the number two lane close to V-gutters be a 24/7 lane closure when they are built?

A2: A 24/7 closure of the number two lane adjacent to the V-gutter may be approved, but it is subject to review and authorization by the City of Lemoore. The contractor must submit a detailed traffic control plan that addresses safety measures, ensures access for emergency services, and minimizes disruption to traffic.

Q3: Since you are awarding the bid on the grand total can we assume that you are going to build all 5 locations?

A3: Awarding the project on the grand total signifies that all five locations outlined in the bid proposal are encompassed within the contract scope. Unless the awarding body issues a change order or otherwise formally amends the contract, the Contractor shall complete work at all five locations in accordance with the bid documents.

Q4: How will changes be paid for if in reconstruct intersection items changes must be made for ADA requirements or other reasons?

A4: No modifications shall be made to any approved plan or drawing unless directed by the Engineer. If ADA requirements or other unforeseen conditions necessitate changes during intersection reconstruction, the Contractor shall submit a written request detailing the scope and cost. These revisions must receive the Engineer's approval and will be compensated in accordance with the contract's change order process.

Q5: How will adjust water valves be paid for?

A5: The items are paid in lump sum.


Q6: AC replacement requirement says heater remixing is required if less than 5 years old. How old is the pavement?

A6: The pavement is older than 5 years.

Q7: Please clarify how the basis of award is determined, given that the Notice to Contractors (NC-2), Section 9 (IB-3), and Section 1.7 (GP-3) each specify the award is based on the “Base Bid,” whereas the Bid Proposal (PF-3) indicates the award is based on the sum of the Base Bid plus all additives.

A7: The project will be awarded based on the Grand Total, which includes the Base Bid plus all additive items. The references to awarding solely on the Base Bid in other sections are superseded by the directive on page PF-3 of the Bid Proposal.

NOTE: One copy of this Addendum Number 2 shall be signed by the Contractor and must be submitted with the bid as an acknowledgment of receipt and the acceptance of this Addendum Number 2.

Prepared by: 

Orfil Muniz, P.E.
A&M Consulting Engineers

March 14, 2025

Date

Accepted by: _____
Contractor (signature)

Date